



Republic of the Philippines  
**CAVITE STATE UNIVERSITY**  
Barangay Indang, Alibon, Cavite  
Indang, Cavite

**BIDS AND AWARDS COMMITTEE**  
(INFRASTRUCTURE PROJECTS)

**SUPPLEMENTAL BID BULLETIN NO. 1**

This Bid Bulletin is issued to modify or amend items in the Bid Documents. This shall form an integral part of the Bid Documents. Please take note of the changes/adjustments to the **Bill of Materials, Imprestment, and Campus - 2 Posting (No. 24-024)**.

1. Site inspection is a must before the start of work.
2. Site temporary enclosure may be sack or any suitable materials that may enclose the work area.

**GENERAL NOTES:**

1. This bid bulletin does not cancel the information given in the scope of work of the Bill of Quantities (BOQ) but adds clarification to it. Please attach this added information/bid bulletin to the BOQ and include in the bid envelope (envélope).
2. The color, type and specification of all fixtures and materials to be used on site should be consulted to the inspector. The contractor should sign the approved sample. Further, the contractor should provide a list of materials to be used and inspected for the extent of work.
3. In case of any change or modification, the contractor should submit a written request to the inspector. Further, whichever is advantageous to the contractor, the contractor may use the materials given in the BOQ.
4. For concrete work, the contractor should use a minimum of 2000 psi concrete.
5. Materials to be used on site must be subjected to material testing which will be charged to the contractor.
6. Let it be observed that all door locks to be installed on doors of all buildings should be of heavy-duty lever type.
7. Multi-plies are allowed for the key personnel who are the signatories and managers of the company.
8. All certifications and permits should be submitted to the inspector. In addition, electrical permits shall be submitted to the relevant authority.
9. Location of temporary warehouse and barracks will be discussed during the pre-construction meeting.
10. All pages of the bidding documents should be originally signed by the authorized signatory (Original, Copy 1 and Copy 2).
11. Use readable font size on the detailed estimate.



**SUBMISSION AND OPENING OF BIDS**

<b>SUBMISSION OF BIDS</b>	<b>August 15, 2024 - 9:30 AM</b> Procurement Office, Cavite State University, Indang, Cavite
<b>OPENING OF BIDS</b>	<b>August 15, 2024</b> S.L. Lasap Hall, Cavite State University, Indang, Cavite  10:00 am – Repainting of University Library 10:30 am – Improvement of Food Processing Building 11:00 am – Repair and Improvement of White House (Convalescence Center for College of Medicine) 1:00 pm – Improvement of Electrical Power System of OLEMU New and Old Building 1:30 pm – Rehabilitation of Concrete Bridge near NORDEC and Pink Dormitory 2:00 pm – Improvement of Electrical Power System of Five-Storey Academic Building at CVSU Bacor Campus

Prepared by:

**MICHELLE A. SANTOS**  
BAC Secretary

**EFREN R. ROCILLO**  
TWG Chair

**EFREN R. ROCILLO**  
TWG Member

**LARRY E. BOCELA**  
TWG Member

**RONALD P. PENA**  
TWG Member

**ELPIDIO N. RODERUS, JR.**  
TWG Member

**RYAN JANSSE**  
TWG Member

Approved by:

**MA. AGNES P. NUESTRO, PhD**  
Chair, BAC for Infrastructure Projects

Received by the Bidder:  
Date: \_\_\_\_\_