



Republic of the Philippines
CAVITE STATE UNIVERSITY

Don Severino Avenue
Indang, Cavite
www.cvsu.edu.ph

BIDS AND AWARDS COMMITTEE
(INFRASTRUCTURE PROJECTS)

SUPPLEMENTAL / BID BULLETIN NO. 1

This Bid Bulletin is issued to modify or amend items in the Bid Documents. This shall form an integral part of the Bid Documents. Please take note of the changes/adjustments for the project **Rehabilitation of Concrete Bridge near NCRDEC and Pink Dormitory (C/S-5-0-0-1NERA-01-000)** with an **AS**.

1. Site inspection shall be conducted on the location of site.
2. Site temporary enclosure may be sack or any suitable materials that may enclose the workplace.
3. The complete set of plans (A1, A2, S1, S2 & S3) -- shows the details and connections of beams and retaining walls.
4. Deformed Bars to be used shall be Grade 60.

GENERAL NOTES:

1. This bid bulletin does not cancel the information given in the scope of work of the Bill of Quantities (BOQ) but only to be used for clarification. Bidders shall include in the financial envelop (envelope 2).
2. The colors, types and specifications of all fixtures and materials to be used on site should be consulted to the inspector or end user for approval. As possible, let the end user or the inspector sign the approved sample. Further, consult the plan and the scope of works as well as the end user and inspector for the extent of materials to be used.
3. In the event that discrepancies on plans and scope of work occurs, generally, the scope of works prevails. Further, whichever is stipulated in the BOQ shall prevail.
4. For concrete works, provide ready-mixed concrete of specified strength.
5. Materials to be used shall be of the best quality which will be arranged with the contractor.
6. Let it be observed that all door knobs to be installed on doors of all buildings be that of heavy-duty lever type.
7. Multi-roles are allowed for the project engineers and managers of the project.
8. All certifications and pertinent documents on electrical works shall have signature of the contractor. In addition, electrical permits shall be up to securing approval from the concerned agency.
9. Location of temporary warehouse and barracks will be discussed during the pre-bid meeting.
10. All pages of the bidding documents shall be signed by the authorized signatory (Original, Copy 1 and Copy 2).
11. Use readable font size on the detailed estimates.





SUBMISSION AND OPENING OF BIDS

SUBMISSION OF BIDS	August 16, 2024, 9:00 AM Procurement Office, Administration Building, Cavite State University Indang, Cavite
	August 16, 2024 S.L. Lasap Hall, Cavite State University, Indang, Cavite 10:00 am – Repairing of University Library 10:30 am – Placement of Rapid Response Building
OPENING OF BIDS	August 16, 2024, 10:00 am Center for Population and Public Health College of Medicine 1:00 pm – Improvement of Electrical Power System of CEMDS New and Old Building 1:30 pm – Rehabilitation of Concrete Bridge near NCRDEC and Pink Dormitory 2:00 pm – Improvement of Electrical Power System of Faculty Academic Building at CWSU Basecamp

Prepared by:


MICHELLE A. SANTOS
BAC Secretary



EFREN R. ROCILLO
TWG Chair


GENE M. BAGO
TWG member



LARRY F. RUYELA
TWG member


RONALD P. PENA
TWG Member


ELPIDIO N. RODEROS, JR.
TWG member


RYAN JANSOK SANCHEZ
TWG member

Approved by:


MA. AGNES S. UNISTED, JR.
Chair, BAC for Infrastructure Projects

Received by: _____
Date : _____